

ಕರ್ನಾಟಕ ಸರ್ಕಾರ

ಸಂಖ್ಯೆ: ವಿ.ಆ/ಬಿ.ಎಲ್.ಡಿ./93/2021-22

ವೈದ್ಯಕೀಯ ಅಧೀಕ್ಷಕರ ಕಛೇರಿ
ವಿಕ್ಟೋರಿಯಾ ಆಸ್ಪತ್ರೆ, ಬೆಂಗಳೂರು-02
ಕಛೇರಿ: 26701150.0, ಫಾಕ್ಸ್: 26703267
ದಿನಾಂಕ : 30-04-2022

ದರಪಟ್ಟಿ ಪ್ರಕಟಣೆ

ವಿಷಯ: ವಿಕ್ಟೋರಿಯಾ ಆಸ್ಪತ್ರೆಯ ಹೊರರೋಗಿ ವಿಭಾಗದಲ್ಲಿ ಅಳವಡಿಸಿರುವ ಕ್ಷ-ಕಿರಣ ಯಂತ್ರದ ಕೊಠಡಿಗೆ ಹವಾನಿಯಂತ್ರಣ ಯಂತ್ರವನ್ನು ಅಳವಡಿಸುವ ಬಗ್ಗೆ.
ಉಲ್ಲೇಖ: ಪ್ರಾದ್ಯಾಪಕರು ಹಾಗೂ ವಿಭಾಗದ ಮುಖ್ಯಸ್ಥರು, ರೇಡಿಯೋ ಡಯೋಗ್ನೋಸಿಸ್ ವಿಭಾಗ ಇವರ ಪತ್ರ ದಿನಾಂಕ: 31-08-2021

* * * * *

ವಿಕ್ಟೋರಿಯಾ ಆಸ್ಪತ್ರೆಯ ಹೊರರೋಗಿ ವಿಭಾಗದಲ್ಲಿ ಅಳವಡಿಸಿರುವ ಕ್ಷ-ಕಿರಣ ಯಂತ್ರದ ಕೊಠಡಿಗೆ ಹವಾನಿಯಂತ್ರಣ ಯಂತ್ರವನ್ನು ಅಳವಡಿಸುವ ಬಗ್ಗೆ. ಕೆ.ಎಸ್.ಟಿ.ಸಿ.ಎಸ್.ಟಿ ವ್ಯಾಟ್ ಮತ್ತು ನಂಬರ್‌ಗಳನ್ನು ಹೊಂದಿರತಕ್ಕ ಸಂಸ್ಥೆಗಳಿಂದ ದರಪಟ್ಟಿಯನ್ನು ಕರೆಯಲಾಗಿದೆ.

Sl.NO	Description of the work	Qty
1.	SupplyingTR split Air conditioners suitable for operation on A/C supply single phase 50 Hz 230 Volts with hermetically sealed compressor with air cooled condenser, motor capacitor and start run capacitors, relay and over load protector internal unit, with one indoor and one outdoor unit The condenser unit will be placed outside the room on the terrace to avoid noise including standard length of suitable size copper tubing covered with insulation tube. (High wall chorded/cordless) suitable capacity 3 core sheathed/ PVC copper cable and a battery operated wireless remote unit	
2.	2 ton capacity	1.0
3.	Installation charges for split type air conditioner with allied works for one indoor and one outdoor unit is to be mounted on suitable Angle Iron support up to 3.0 ton split/cassette type A/C.	1.0
4.	Supplying and installation of insulated refrigerant copper tubing of 5/8" and 3/8" with polythene foam insulation 3 core 80 stand copper wiring between indoor and outdoor unit Leak testing oil and gas charging for additional piping length of tube.	
5.	Split	5.0
6.	Extra for Fabrication supply and fixing of Stand fabricated using slotted angle /L angle of size 6mm x 50mm for mounting out door/indoor A.C. unit/ Batteries.	1.0
7.	Supplying and fixing of modular switch & connected accessories on existing modular switch plate as per IS 3854 and IS 1293.	
8.	16Amps one way switch	2.0
9.	6/16Amps universal socket	2.0
10.	Supplying and fixing miniature circuit breakers on existing MCB distribution boards using necessary fixing materials and 'C' Type curve, indicator ON/OFF, energy cross-3 with Short circuit breaking capacity of 10K and complete wiring as required confirming to IEC 60898.	
11.	6-32Amps DP	1.0
12.	Wiring for lighting/power circuit using one of FRLS PVC insulated 1100V grade, multistrand copper wire with low conductor resistance single core in	

	open or concealed system of wiring with specified IS-694:confirming to latest amendments.	
13.	1.5 sqmm	60.0
14.	4 sqmm	60.0
15.	2.5 sqmm	60.0
16.	Supplying and fixing surface/flush mounting unbreakable PVC modular box suitable for mounting modular switch plates with due groove cutting in Brick/C.C wall, including necessary rawl plugs, Machine/NF screws etc., complete.	
17.	1-3Way	1.0
18.	Supplying and fixing superior quality modular switch mounting polycarbonate plate with necessary supporting back plate with required nos. of machine screws, bolts nuts etc., complete on the existing metal/PVC box.	
19.	1 to 3 Module	1.0
20.	Supplying, erecting, testing and commissioning of voltage stabilizer suitable for 170 to 270 V input and load variation from no load to full load, with over load protection, spike suppression, operating at 00 C to 400 C. Range etc., complete.	
21.	4KVA Capacity	1
22.	Supplying heavy gauge PVC conduit pipe dia mm thick confirming to IS 2509 with suitable size bends, junction boxes, adhesive paste etc , and fixing using inverted wood plugs in case of RCC ceiling and RCC wall/ stone structure or rawl plugs in case of brick walls and cement plastering the damaged portion using heavy gauge saddles at an interval of 700mm using NF screws.	
23.	19/20mm dia 2mm thick	30

1. ಮೊಹರು ಮಾಡಿದ ದರಪಟ್ಟಿಯನ್ನು ಈ ಆಸ್ತಿಯ ವೈದ್ಯಕೀಯ ಅಧೀಕ್ಷಕರು, ವಿದ್ಯಾರಣ್ಯ ಆಸ್ತ, ಬೆಂಗಳೂರು ರವರಿಗೆ ದಿನಾಂಕ: 11/5/22 ರಂದು ಮಧ್ಯಾಹ್ನ 3:00 ಘಂಟೆಯೊಳಗೆ ತಲುಪುವಂತೆ ಸಲ್ಲಿಸತಕ್ಕದ್ದು.
2. ಮೊಹರು ಮಾಡಿದ ಲಕೋಟಿಯ ಮೇಲೆ ಹೊರರೋಗಿ ವಿಭಾಗದಲ್ಲಿ ಅಳವಡಿಸಿರುವ ಕ್ಷ-ಕಿರಣ ಯಂತ್ರದ ಕೊಠಡಿಗೆ ಹವಾನಿಯಂತ್ರಣ ಯಂತ್ರವನ್ನು ಅಳವಡಿಸುವ ಬಗ್ಗೆ. ದರಪಟ್ಟಿ ಪ್ರಕಟಣೆ ಸಂಖ್ಯೆ: ಎ.ಆ/ಬಿ.ಎಲ್.ಡಿ./93/2021-22 ಮತ್ತು ದಿನಾಂಕ: 30-4-22 ವನ್ನು ನಮೂದಿಸಬೇಕು.
3. ನಿಗದಿತ ಅವಧಿ ಮೀರಿ ಬಂದಂತಹ ಲಕೋಟಿಗಳನ್ನು ಪರಿಗಣಿಸಲಾಗುವುದಿಲ್ಲ.
4. ಸಲ್ಲಿಸಿರುವ ದರಪಟ್ಟಿಗಳನ್ನು ಯಾವುದೇ ಕಾರಣಗಳನ್ನು ನೀಡದೆ ಅಂಗೀಕರಿಸುವುದು ಅಥವಾ ತಿರಸ್ಕರಿಸುವುದು ವೈದ್ಯಕೀಯ ಅಧೀಕ್ಷಕರ ಅಧಿಕಾರ ವ್ಯಾಪ್ತಿಗೆ ಒಳಪಟ್ಟಿರುತ್ತದೆ.

ವೈದ್ಯಕೀಯ ಅಧೀಕ್ಷಕರು
ವಿದ್ಯಾರಣ್ಯ ಆಸ್ತ, ಬೆಂಗಳೂರು

ಪ್ರತಿಯನ್ನು :-

1. ನಿರ್ದೇಶಕರು ಹಾಗೂ- ಡೀನ್, ಬಿ.ಎಂ.ಸಿ.ಆರ್.ಐ. ಬೆಂಗಳೂರು.
2. ವೈದ್ಯಕೀಯ ಅಧೀಕ್ಷಕರು, ಬೌರಿಂಗ್ ಮತ್ತು ಲೇಡಿ ಕರ್ಜನ್ ಆಸ್ತ, ವಾಣಿ ವಿಲಾಸ್ ಆಸ್ತ, ಮಿಂಟೋ ಕಣ್ಣಾಸ್ತ, ಸಾರ್ವಜನಿಕ ಆಸ್ತ, ಜಯನಗರ, ಎಸ್.ಡಿ.ಎಸ್.ಟಿ.ಬಿ ಆಸ್ತ, ಎಚ್.ಎಸ್.ಐ.ಎಸ್.ಫೋಷಾ ಆಸ್ತ, ಕೆ.ಸಿ.ಜನರಲ್ ಆಸ್ತ, ಬೆಂಗಳೂರು. ಇವರಿಗೆ ಸೂಚನಾ ಫಲಕದಲ್ಲಿ ಪ್ರಕಟಿಸಲಾಗಿದೆ.
3. ಸೂಚನಾ ಫಲಕ /ಕಛೇರಿ ಪ್ರತಿ.
4. ಪ್ರಾಧ್ಯಾಪಕರು ಹಾಗೂ ವಿಭಾಗದ ಮುಖ್ಯಸ್ಥರು, ರೇಡಿಯೋ ಡಯೋಗ್ನೋಸಿಸ್ ವಿಭಾಗ ವಿದ್ಯಾರಣ್ಯ ಆಸ್ತ, ಬೆಂಗಳೂರು.
5. ಸಿವಿಲ್ ಇಂಜಿನಿಯರ್, ಬಿ.ಎಂ.ಸಿ.ಆರ್.ಐ, ಬೆಂಗಳೂರು
6. ಮೇಲ್ವಿಚಾರಕರು, ತುರ್ತು ಚಿಕಿತ್ಸಾ ಘಟಕ, ವಿದ್ಯಾರಣ್ಯ ಆಸ್ತ, ಬೆಂಗಳೂರು.
7. ವಿಶೇಷ ಸೂಚನೆ: ಸರ್ಕಾರದ ಆದೇಶ ಸಂಖ್ಯೆ: ಎಸ್.ಡಬ್ಲ್ಯೂ.ಡಿ 34 ಬಿಸಿಎ 2004, ಬೆಂಗಳೂರು ದಿ: 10-03-05 ಪರಿಶಿಷ್ಟ ಜಾತಿ, 2. ಪರಿಶಿಷ್ಟ ಪಂಗಡ, 3. ಇತರೆ ಹಿಂದುಳಿದಿರುವ ಸಂಸ್ಥೆಗಳು, ಮತ್ತು ಅಲ್ಪ ಸಂಖ್ಯಾತರುಗಳಿಗೆ ಅದ್ವೈತ ನೀಡಲಾಗುವುದು. (ದರಪಟ್ಟಿಯೊಂದಿಗೆ ಸಂಬಂಧಿಸಿದ ಸರ್ವಿಫಿಕೇಟ್ ಪ್ರತಿಯನ್ನು ಲಗತ್ತಿಸುವುದು)